

James McWilliam

From: Sanderson, Iain [REDACTED]@gcu.ac.uk>
Sent: 07 February 2018 09:21
To: Kilpatrick, Tony; CONNOLLY, Bill (NHS NATIONAL SERVICES SCOTLAND); STEELE, Tom (NHS NATIONAL SERVICES SCOTLAND)
Subject: Re: FYI re cladding Screen Shots of appropriate pages.

Draft of Final QEUH Jan 2018 Amend 25-01-18 (2) - Microsoft Word

File Home Insert Page Layout References Mailings Review View Acrobat Design Layout

Clipboard Font Paragraph

Navigation

celotex

1 of 4 matches

- single glass spandrel panels with Celotex FR5000 insulation, internal steel tray panel.
- flame of curtain walling Class 0 to BS 476-7. Celotex FR5000; Fire propagation BS476 part 6- Pass;
- spandrel panels - Alucobond PE, with Celotex FR5000 insulation, internal steel tray panel.
- flame of curtain walling Class 0 to BS 476-7. Celotex FR5000; Fire propagation BS476 part 6- Pass;

1	5	6	9	10	11	12
Project	Location	Reference	(If col 6 completed): External wall construction	(If col 7 completed): Relevant fire classifications	(If col 6 completed): Firestopping in Void?	Special Contr Description
The Queen Elizabeth University Hospital and Royal Hospital for Children, Glasgow	Adults, Towers	1	Unitised curtain walling system fixed at floor slab levels incorporating double glazed units with fully encapsulated insulated aluminium spandrel panels, independent shaftwall system forming internal leaf clad with two layers of plasterboard to inner face and cement particle board to outer face	Reaction to fire of external wall cladding to be low risk in accordance with non-domestic technical handbook section 2.7.1	Intumescent firestops are provided horizontally at each floor level, around all window & door openings and vertically at all compartment wall junctions	Unitise curtain incorp double units, encaps glass s panels FR5000 interna panel.

Page: 12 of 29 Words: 5,671

Type here to search

Draft of Final QEUH Jan 2018 Amend 25-01-18 (2) - Microsoft Word

File Home Insert Page Layout References Mailings Review View Acrobat Design Layout

Clipboard Font Paragraph

Navigation

celotex

3 of 4 matches

- single glass spandrel panels with Celotex FR5000 insulation, internal steel tray panel.
- flame of curtain walling Class 0 to BS 476-7. Celotex FR5000; Fire propagation BS476 part 6- Pass;
- spandrel panels - Alucobond PE, with Celotex FR5000 insulation, internal steel tray panel.
- flame of curtain walling Class 0 to BS 476-7. Celotex FR5000; Fire propagation BS476 part 6- Pass;

The Queen Elizabeth University Hospital and Royal Hospital for Children, Glasgow	Adult, Towers	9	Unitised curtain walling system incorporating double glazed units with fully encapsulated spandrel panels formed of Reynobond aluminium panels incorporating Kingspan Kooltherm K12 thermal insulation, independent shaftwall system forming internal leaf clad with two layers of plasterboard to inner face and cement particle board to outer face	Reaction to fire of external wall cladding to be low risk in accordance with non-domestic technical handbook section 2.7.1	Intumescent firestops are provided horizontally at each floor level, around all window & door openings and vertically at all compartment wall junctions	Unitise curtain incorp double units, encaps compo alumin panels PE, wit FR5000 interna panel.
--	---------------	---	---	--	---	---

Page: 18 of 29 Words: 1/5,671

Dr Iain A Sanderson

Lecturer

Fire Risk Engineering Programme

Glasgow Caledonian University

School of EBE

70 Cowcaddens Road

Glasgow

G4 0BA

Tel:

Mob:

Fax:

From: Kilpatrick, Tony
Sent: 07 February 2018 09:00
To: CONNOLLY, Bill (NHS NATIONAL SERVICES SCOTLAND) [REDACTED]@nhs.net); STEELE, Tom (NHS NATIONAL SERVICES SCOTLAND)
Cc: Sanderson, Iain
Subject: RE: FYI re cladding

It appears that this may have been used in QEUH and therefore could open up the debate, Iain going to check the table of materials.

From: Kilpatrick, Tony
Sent: 07 February 2018 08:53
To: CONNOLLY, Bill (NHS NATIONAL SERVICES SCOTLAND) [REDACTED]@nhs.net); STEELE, Tom (NHS NATIONAL SERVICES SCOTLAND)
Cc: Sanderson, Iain
Subject: FW: FYI re cladding

You may have this, if not FYI, may or may not make a change to the pressures.

Tony

From: Sanderson, Iain
Sent: 07 February 2018 08:01
To: Kilpatrick, Tony; Hay, Bill; [REDACTED]
Subject: FYI re cladding

https://www.shponline.co.uk/grenfell-labour-warns-national-fire-testing-regime-tatters/?cid=%3FCID%3Dema-Newsletter_SHP%20Plus%20Weekly-6th%20February%202018-Read%20the%20full%20article-

Dr Iain A Sanderson
Lecturer
Fire Risk Engineering Programme
Glasgow Caledonian University
School of EBE
70 Cowcaddens Road
Glasgow
G4 0BA
Tel: [REDACTED]
Mob: [REDACTED]
Fax: [REDACTED]

Glasgow Caledonian University is a registered Scottish charity, number SC021474